

DE DE LUCIE COUNTY

Permit Status Lookup

Click here to return to the main Permits page.

Print in

Please Enter Permit #:

OR Enter Parcella or fax su.

(without special characters)

1745.077

(Anti Press ! ----

(And Press * -

Use this search feature to obtain building permit information also contact the Permitting division at (772) 462-1553 or musiastiucieco.org

Address: 10152 S OCEAN DR BLDG B/PROJ.

JENSEN BEACH, FL 34957

Job Description: REMOVE EXISTING MODIFIED ||Number Units: 1 BIT SYSTEM DOWN TO DECK. PRIME DECK TORCH BASE DIRECT TO DECK TORCH MODFIED OVER BASE, 17400 SO FT FLAT ROOF. (EMERGENCY DUE TO HURRICAME DAMAGE).

IlPermit Number: 1710-0554 iiPermit Type: ROOF -

CUMMERCIAL"

#Status: Finaled

||Zoning: HUTCHINSON ISLAND RESIDENTIAL DEVELOPMENT

Date Applied: 10/23/2017

STATE OF THE PARTY Wiew property data;

Subdivision: 4502803 Biock:

diction; CTY

•	Reviewed By	Date Started	Date Sent	Department	Date Completed	Review Type	Review Status
1	aivensd	10/23/2017	10/23/2017		10/23/2017	FRONT COUNTER REVIEW	COMPLETE
1	roceberry	11/1/2017	10/23/2017		12/7/2017	PLANS EXAMINER REVIEW	COMPLETE
1	ingram!	12/8/2017	12/8/2017		12/8/2017	NOTIFIED FOR PICK UP	COMPLETE

Review Type

Computance Comment

Jate

EXAMINER

12/7/2017 11/1/2017

AS PER OUR PHONE CONVERSATION, PLEASE SUBMIT SITE SPECIFIC ENGINEERING FOR DESIGN PRESSURE UPLIFT REQUIREMENTS. AND APPROVING PRODUCT APPLICATION SUBMITTED.

"HELDER SERVE	Inspector Name	Inspection Type	Date Updated	Date Scheduled	Inspection Status	Date of inspection	Scheduled By	Permit Number	Inspector Comments
-	GARY SCHEIGNER	ROOF DRY-IN/TIN TAB	7/25/2018	12/29/2017	Approved	12/29/2017	WEB	1710-0554	
- Withhelman	GARY SCHEIGNER	PROGRESS INSPECTION	8/8/2018	8/8/2018	Approved	8/8/2018	WEB	1710-0554	WAS SIGNED OFF ON CARD- ASSUMING BY GARY
- salbasedar-	GARY SCHEIGNER	FINAL INSPECTION	8/8/2018	8/8/2018	Final Approval	8/8/2018	WEB	1710-0554	